

Front View Dimensions:
 Total height: 2150
 Width: 572
 Height to top of unit: 1623
 Height to base of unit: D 576
 Distance from floor to base: 203
 Distance from floor to unit base: 77

Side View Dimensions:
 Top width: 452
 Distance from wall to unit: 226
 OD 150 (chimney pipe)
 Distance from floor to top of unit: A 1312*
 Distance from floor to base of unit: B 1192*
 Distance from floor to base of unit: C 587
 Distance from floor to base of unit: 138
 Toevoerluchtaansluiting Ø67 (air intake connection)

De afstand vóór de kachelopening tot aan brandbare bouwdelen of inrichting dient minimaal 1,1 m te bedragen.

Op de maatschetsen worden alleen de minimaal toegestane installatieafstanden voor de kachel aangegeven. Bij aansluiting op een stalen schoorsteen moeten ook de eisen met betrekking tot veiligheidsafstanden voor de schoorsteen in acht worden genomen. De veiligheidsafstand tussen een ongeïsoleerde schoorsteenpijp en brandbare bouwdelen moet minimaal 300 mm bedragen.

A = hoogte van vloer tot schoorsteenaansluiting, boven
 B = hoogte van vloer tot schoorsteenaansluiting (h.o.h.), achter
 C = hoogte van vloer tot toevoerluchtaansluiting
 D = hoogte van vloer tot onderkant deur
 ID (Binnendiameter)
 OD (Buitendiameter)

INSTALLATIE OP EEN BRANDBARE WAND

Dimensions for Combustible Wall:
 Wall thickness: 262
 Distance from wall to unit: 262
 Distance from wall to unit: 996
 Distance from wall to unit: 546
 Distance from wall to unit: 830
 Distance from wall to unit: 326
 Distance from wall to unit: 432
 Distance from wall to unit: 718
 Distance from wall to unit: 275
 Distance from wall to unit: 275
 Toegestaan gebied voor brandbaar bouwdeel (permitted area for combustible building part)

INSTALLATIE OP BRANDMUUR

Dimensions for Non-Combustible Wall:
 Wall thickness: 800
 Distance from wall to unit: 50
 Distance from wall to unit: 697
 Distance from wall to unit: 800
 Distance from wall to unit: 333
 Distance from wall to unit: 616
 Distance from wall to unit: 50
 Distance from wall to unit: 770
 Distance from wall to unit: 50
 Distance from wall to unit: 276
 Distance from wall to unit: 1100
 Distance from wall to unit: 200**
 Distance from wall to unit: 486**

* Als de kachel op een vloerplaat van bijvoorbeeld glas (accessoire) komt te staan, wordt de dikte van de vloerplaat bij de hoogte vanaf de vloer opgeteld. Voor een vrijliggende glazen vloerplaat geldt 10 mm.

** Om verkleuring van geschilderde onbrandbare wanden te voorkomen, bevelen wij dezelfde zijafstand aan als voor brandbare wanden.